DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Robert Bass OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 5-2-94
PROPOSED FACILITY: 3bedroom, DW MH
PROPERTY SIZE: 125 x 500
LOCATION OF SITE: Waterlynn Road
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS 2%	0-16	SAB/cL	1:1/fi			PS		.4
		16-25	SAB/C	1:1/vfi					.3
		25-48	SAB/cL	1:1/fi					.4
2	LS ~2%	0-18"	SAB/cL	1:1/fi-fa			PS		.4
		18-48"	SAB/C	1:1/fi-vfi					.3
3									
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: Hole #2 - numerous relic mottles beginning Approx 45"