IREDELL COUNTY HEALTH DEPARTMENT 4656-16-5257

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy F. Caldwell DATE 7-8-83 PERMIT NO. 22

PHONE: Business _____ Home _____

LOCATION 215 N Deerwood Lane .1mile on R

_____ S. R. No. _____

SUBDIVISION NAME Deerwood LOT NO. 14 SECTION OR BLOCK NO. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No X	Character & Porosity of Soil	Clay loam/Clay
Auto. Dishwasher	Yes X	No ( )	Percolation Rate	0 bpf 1st 24 hrs/Many
Auto. Wash. Machine	Yes X	No ( )	Topography	10-15%
Site Suitable	Yes X	No ( )	Depth to Water Table	44"
			Rock or other impervious formations	None observed

Lot Area 30,000FT²

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 960 Linear Ft. _____
Depth of Stone in Lines 12"

Water Supply: Individual X
Public ( )

Installed by J.R. Bowles

I understand and agree to install septic tank system as specified on this Improvement Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY: Fred Clemmer DATE 7-8-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold