IREDELL COUNTY HEATLH DEPARTMENT

PAGE 2: *SITE PLAN WORKSHEET*

SEE THE SAMPLE SITE PLAN BELOW. INCOMPLETE SITE PLANS WILL BE RETURNED TO YOU FOR COMPLETION AND MAY RESULT IN A DELAY IN THE ISSUANCE OF YOUR SEPTIC SYSTEM PERMIT!!!

Place an (X) beside each item as you complete the site plan:

- ✓ **Property Line measurements are clearly identified…**
- C **All proposed structures are indicated…**
- ✓ ***SHOW: proposed house or business footprint, wells, water lines, patios, pools and decks, and any other item that will occupy space on the site***
- ___ **Front and side setbacks from property line…**
- ___ **Preferred driveway location and configuration, preferred well location…**
- ✓ **Area you prefer your septic system to be placed…**
- ___ **North arrow, or other sufficient indicator of direction…**


Circle N/A on the following if appropriate:

- ___ **Location of septic systems and wells within 100' of your property… N/A**
- ___ **Location of easements and rights of ways on your property… N/A**
- ___ **Location of any designated wetlands on the property… N/A**


Signature: Tim Porter
Property owner or owner's legal representative signature (SIGNATURE REQUIRED)

March 6, 2013
DATE

USE THIS SPACE TO DRAW YOUR SITE PLAN




Pin # 4656260474.00



Built 1975

643
459

Frank & Susan Rick & Nancy Drum & Poore



Aloha Pools Tim 980-722-1453

Jeff & Tanya Barbare
169 Deerwood Ln.
Mooresville, NC 28117
Pin# 4656260474.00

4656 26 0474

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rick Drum DATE 9-27-74 PERMIT NO. 270

PHONE: Business _____ Home _____

LOCATION US 21 South TL after Cross Lake Norman

S. R. No. _____

SUBDIVISION NAME Pope Property LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 6 acres


Character & Porosity of Soil Sandy Clay loam porosity good

Percolation Rate 8 min/ Inch

Topography 2% Slope

Depth to Water Table 10' ±

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 175 Linear Ft. 270

Depth of Stone in Lines 12" to 15"

Water Supply: Individual (✓)

Public ( )

Installed by Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

The proposed / existing Deck addition does not appear to impact the existing septic system.

**NOTE: Foundation shall be min. 5' from septic system

Cindy Melville R.S.

Date: 5-30-12

ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY John Houston DATE 9-27-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold