4656291753

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR K.C.(R) Development Corp. DATE 6/22/88 PERMIT NO. _____

PHONE: Business 663-2220 Home _____

LOCATION 21 S. on R. Past X W/ 1100

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 1 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other employee

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
~~Site Suitable~~ P.S.	Yes (✓)	No ( )	

Character & Porosity of Soil clayey

Percolation Rate .3gpd/A ±


Topography 2%

Depth to Water Table 4'+

Rock or other impervious formations none observed

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 (Taylorsville) Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 480 Linear Ft. 160

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Wayne Ford

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 6/22/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

1100

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR K. C. (R) Development Corp. DATE 5/23/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION ~~HS~~ 21 S. on R. past X w/ 1100.

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 1 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (X) Other 1 employee


No. Bedrooms 0 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No (✓)	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clayey
Percolation Rate .3 gpd/ft²
Topography 2%
Depth to Water Table 4+
Rock or other impervious formations none obs.

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: Install system shallow and ON contour.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold