DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: ID 18 41
PROPERTY RECORDED: NO
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: B H MILLER OWNER: AGENT: PHONE: 663-4805
ADDRESS: ALMOND ST APPLICATION DATE: 5/27 DATE EVALUATED: 6/2/93
MOORESVILLE PROPOSED FACILITY: 2 2 BDRM MH'S
PROPERTY SIZE: 150' X 260'
LOCATION OF SITE: MACKWOOD TR ON ALMOND ON (R) JUST PAST 2ND HOUSE
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-6	wk GRAN	1:1	SF	N/A	P		
		7-24	wk SBK	1:1	F	N/A	P		
		24-35	GRAN-SBK	1:1	F,	N/A		P	
		35-44	TRANS / GRAN	L	F	N/A	P	P	.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: W Sparks OTHER(S) PRESENT:
COMMENTS: