DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2326
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BILL MILLER OWNER: ✓ AGENT: PHONE: 663 - 4309
ADDRESS: Rt 11 Box 115 APPLICATION DATE: 4/3/93 DATE EVALUATED: 5/27/93
MOORESVILLE PROPOSED FACILITY: 2 - 2 BEDROOM M.H.
PROPERTY SIZE: 150' x 260'
LOCATION OF SITE: ALMOND RD / 115 S TL MACKWOOD TR ALMOND 4.5 JACKSON (R)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	1%	0-8	cl		SF	No	P	P	.125-.3
		9-26	c						
		27-42	scl	1:1					
2	3%	0-11	cl		SF	SP	P	P	.25
		12-30	c						
		31-48	scl	1:1	SF				
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .25 - (.3)
EVALUATED BY: Sparks OTHER(S) PRESENT: Bill Miller
COMMENTS: D/W at rear of property ~ 30' from P/L