IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul Calloway DATE 11-2-81 PERMIT NO. 338

PHONE: Business _____ Home _____

LOCATION 115 S. SR 1132 x RR Tr 3rd house on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2 80
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk.
			Rock or other impervious formations	none obs.

Lot Area Existing

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 540 Linear Ft. 180
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DLH

COMMENTS: Old line disconnected

CERTIFICATE OF COMPLETION BY David Hinson DATE 11-2-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold