DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jerry Styers OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 2/28/94
PROPOSED FACILITY: 4 bedroom Duplex
PROPERTY SIZE:
LOCATION OF SITE: 1155 TR Sonsquiac Rd. on Rt just past 1st EX. House
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-3"	SAB/CL	1:1 FR			PS		.25-.3
		3-30	SAB/C	1:1 FI					
		30-48	WKSAB/CL SAP Lens	1:1 FR					
3									
4									
5									

SUITABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: OTHER(S) PRESENT: Jerry Styers
COMMENTS: