4656 58 3494

0448

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James D Davis Jr. DATE Feb 10, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Lawrance Ave. Turn on Norman Drive Bear Lt. on Club Drive At end of Cul-D-Sac S. R. No. _____

SUBDIVISION NAME Wilton Forest LOT NO. 9&10 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ OK Yes (✓) No ( )

Lot Area 20000ft²+

Character & Porosity of Soil clay like transition to sapralyte


Percolation Rate 2.4

Topography 4-8%

Depth to Water Table 41+

Rock or other impervious formations none obs.

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. _____ Linear Ft. 450'

Depth of Stone in Lines 16" Top

Water Supply: Individual ( ) Public (✓) Panels

Installed by Rowan Septic Tank

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 2/10/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold