Mooresville
904

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Maxwell Hinshaw DATE 6/9/88 PERMIT NO.

PHONE: Business Home 664-2611

LOCATION S. Broad TR Lowrance TL Norman TR Club.

S. R. No.

SUBDIVISION NAME Wilton Forest LOT NO. 13 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 3-2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	3
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	8%
Site Suitable PS.	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none obsved.

Lot Area 24,798 ft²

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System NOT TO SCALE

Pump tank: 1000gal

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 200' of 16" T & J
Sq. Ft. Linear Ft. Panels.
Depth of Stone in Lines

Water Supply: Individual ( )
Public (✓)

Mooresville city.

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: L. G. Brown

IMPROVEMENTS PERMIT BY Andrew C. Pierce

COMMENTS: Set tanks 15' from house. Pump thru solid 2" schedule 40 PVC to drainfield. valve at head of each ditch. Shallow drainfield (6"-8" cover.) Installe according to Manufacturer specs. High water alarm must be installed on separate circuit.

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: and checked. 2' pressure head on each ditch. DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold