IREDELL COUNTY HEALTH DEPARTMENT 4656 68 2678

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth & Susan Stoltzfus DATE 10/7/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Lowrence Ave Turn on Norman Drive Bear Right on Club Dr. ~ 1/8 mile on Right S. R. No. _____

SUBDIVISION NAME Wilton Forest LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay
Percolation Rate ~.4 gpd/ft²
Topography 4-8%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 20000 ft²+

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓) Municipal (Mooresville)

Installed by ABERNATHY

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D.R.H., R.S.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Grace DATE 10/9/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow [illegible] Owner's Copy: Gold