Mooresville
gle 5

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

4656-68-4702

OWNER OR CONTRACTOR Charles Baker DATE Sept. 1, '88 PERMIT NO.

PHONE: Business Home (609) 424 - 2299

LOCATION S. BROAD ST. TR LAWRENCE TL NORMAN TR Club 2nd lot on R. (~~122~~ 121 Club Dr.) S. R. No.

SUBDIVISION NAME WILTON FOREST LOT NO. 2 SECTION OR BLOCK NO.

MOORESVILLE CITY LIMITS

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey

Percolation Rate ~.35 gpd/ft²


Topography Gently

Depth to Water Table 4'+

Rock or other impervious formations none observed.

Lot Area 15000ft²

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



P.T. 1250

Size of Tank ~~S~~ 1250 Gals.

Nitrification Field:

No. of Lines 170' of 16" T&J

Sq. Ft. ___ Linear Ft. PANELS.

Depth of Stone in Lines ___

Water Supply: Individual ( )

Public (✓)

MOORESVILLE

Installed by WAYNE ORBISON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ___

IMPROVEMENTS PERMIT BY ACP

COMMENTS: 2' of Pressure head on ea. ditch. Best cover over lines is Fescue lawn grass. DO NOT MULCH OVER SYSTEM.

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 9-1-88

EXISTING SYSTEM CHECKED BY: ___ DATE ___

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold