MOORESVILLE
865

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Baker DATE 4/21/88 PERMIT NO. _____

PHONE: Business _____ Home (609) 424-2299

LOCATION S. BROAD ST. TR LOWRANCE T/L Norman TR Club 2nd lot on R. (122 Club Dr.) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable P.S.	Yes	( )	No	( )	

Lot Area 15000ft² 32

Character & Porosity of Soil Clayey
Percolation Rate ~.35 gpd/ft²
Topography Gently
Depth to Water Table 4'+
Rock or other impervious formations none observed. PM at 48"

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

1250 gal - P.T.
Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2 lines @ 170' of
Sq. Ft. _____ Linear Ft. 16" T & J
Depth of Stone in Lines Panels
Water Supply: Individual ( ) PRESSURE DOSED.
Public (X)

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Charles F. Baker

IMPROVEMENTS PERMIT BY Andrew C. Peirce

COMMENTS: Pump through 2" Sch 40 PVC to drainfield (pressure dosed panels.) Ball valve at head of ea. ditch. 2' pressure head on each drainfield ditch. Install float switch and high water alarm switch in pump tank. High water alarm will be mounted in living area and checked b/f completion.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold