4656-68-5728
111 Club Dr.
L 1 Wilton Forrest

1612

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Andy Smith DATE 5/31/91 PERMIT NO. IJ 33 A 1

PHONE: Business _____ Home _____

LOCATION South Broad St. TR Lawrence Ave TL on Norman Dr. TR on Club Dr. 1st lot on ®

S. R. No. _____

SUBDIVISION NAME Wilton Forest LOT NO. 1 SECTION OR BLOCK NO. 1

Mooresville City Limits

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 135' x 190'

Character & Porosity of Soil ps clay / transition saprolite


Percolation Rate .35

Topography 15%

Depth to Water Table >48"

Rock or other impervious formations None observed

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

1250 pump tank

Size of Tank 1250 S/T Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. _____ Linear Ft. 180'

Depth of Stone in Lines _____

Water Supply: Individual ( ) 16" T+J Panel Pressure Dome

Public ( )

Installed by Richard Abernethy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Electrical connections for pump and alarm are to be on seperate 110 circuits from each other. Dosing approximately 150-200 gallons per dose. Head set a 2' of head per lateral.

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 5/31/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold