Site Address: 130 Oak Park Dr - Mooresville

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 147617 PIN# ~~4724432699~~ 4656-93-1606 DATE 5-14-08

OWNER OR APPLICANT JEFFREY MEDLEN PHONE: Business 843-252-8280 Home 843-228-5127

ADDRESS 208 BEVERLY Anne Dr Statesville NC 28677

LOCATION BUFFALO SHOALS SOUTH WEST ⓑ Pinewille Rd ⓛ Beverly Anne ATEND ON LEFT

SUBDIVISION Timber Ridge BLOCK / SECTION 3 LOT 12 LOT AREA _____ SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 760 Date 3-10-08
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 1200' Linear Feet 400'
No Lines 4x100 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI
System Description: GRAVITY CONVENTIONAL
Repair System Description: SAME
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 3 No. Persons 6 No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth 12" ☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: ① DO NOT CUT For Positive Drainage REQMTS. Keep House Out of Ground & Backfill for Positive drainage reqmts if necessary ② CALL HEALTH DEPT IF Any Questions Arise

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LORNE LOOK, R.S.

Comments/Conditions: ③ "An Accepted System CAN BE USED"

TANK IS 9' OFF Proposed House Corner

AS BUILT SKETCH

WELL IS 110' to 1st Drain line
WELL IS 85' to TANK
OWNER AUTHORIZED SYSTEM CHANGES
System Installed BY [redacted] House
WAS BUILT. TANK 9' OFF PROPOSED CORNER OF HOUSE.
POLYLOK Fill & MULCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 21 MAY 08 Installed by: A-1 BACKHOE

Improvement Permit by: _____ date 5-14-08 Operation Permit by: _____ date 6/26/08

Authorization to Construct by: _____ date 5-14-08 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

Permit # 147617

Pin # 4721132699

CUT OVER SCRUB TIMBER LAND

709

(690)

