1325

4657126728

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dora Jones DATE Mar 15, 1990 PERMIT NO. 1K2-A-15

PHONE: Business _____ Home _____

LOCATION 215 TR Dry Dock Loop On back side of loop

SUBDIVISION NAME Lakeview Development LOT NO. 15 SECTION OR BLOCK NO. _____ S. R. No. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ OK Yes (✓) No ( )
Lot Area 20,000

Character & Porosity of Soil clayey
Percolation Rate ~.4 gpd/ft²
Topography 5% 12%
Depth to Water Table + 3'
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3 @ 67'
Sq. Ft. 600' Linear Ft. 200'
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by F J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____ Lot # 14

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Sam Ingram Eff B DATE Mar 15, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold