4657137034

1347

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dora Jones DATE Mar 14, 1990 PERMIT NO. IK-2-A, 18

PHONE: Business _____ Home _____

LOCATION 215 TR Dry Dock Loop On back side of loop

S. R. No. _____

SUBDIVISION NAME Lakeview Development LOT NO. 18 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clayey
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	~.4 gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	5-12%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	+3'
			Rock or other impervious formations	none obs.

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines ~~2~~ 3@67

Sq. Ft. 600 Linear Ft. 200'

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by FJ Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Sam Ingram EHS DATE Mar 14, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold