IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dogwood Const. Co. DATE 3-28-74 PERMIT NO. 57

PHONE: Business 528-5700 Home

LOCATION 150 west TR on 1116

S. R. No. 1116

SUBDIVISION NAME Homestead Estates LOT NO. 13 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 Sq Ft

Character & Porosity of Soil Fine Sandy Clay loam
Percolation Rate 55 min/inch
Topography < 2% Slope
Depth to Water Table 10+
Rock or other impervious formations 5 to 15' to bedrock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1125 Linear Ft. 375
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-28-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold