IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dogwood Const. Co. DATE 2-28-74 PERMIT NO. 22

PHONE: Business _____ Home _____

LOCATION N.C. 150 west TR on 1116 1st house on right

S. R. No. _____

SUBDIVISION NAME Homestead Estates LOT NO. 20 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 16,000 Sq feet

Character & Porosity of Soil Cecil Clay & gravel clay Porosity moderate to good
Percolation Rate 37 min/inch drop
Topography 3% Slope
Depth to Water Table 10'
Rock or other impervious formations none



Plot of System P. Line

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 810 Linear Ft. 270
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: (good construction)

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 2-28-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

73

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold