IREDELL COUNTY HEALTH DEPARTMENT 4657 184980

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H. D. Smith DATE 6-19-96 PERMIT NO. 12

PHONE: Business Education Home

LOCATION NC 21 Hwy has TR on L 305 feet

SUBDIVISION NAME Great Heritage LOT NO. 1 SECTION OR BLOCK NO.

S. R. No.


House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms No. Bathrooms

Garbage Disposal Unit	Yes	( )	No	( )
Auto. Dishwasher	Yes	( )	No	( )
Auto. Wash. Machine	Yes	( )	No	( )
Site Suitable	Yes	( )	No	( )

Lot Area 1 acre +

Character & Porosity of Soil Clay loam (Mostly Fill)
Percolation Rate 3 to 5 min to 2 inches
Topography
Depth to Water Table
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 450
Depth of Stone in Lines 24"
Water Supply: Individual ( )
Public ( )

Installed by H.D. Smith Const.

Septic 5'x125' 3 lines

IMPROVEMENTS PERMIT BY J. C. Miller

COMMENTS:

CERTIFICATE OF COMPLETION BY H. D. Smith Const. DATE 6-19-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold