4657194075

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR R. Smith Builders DATE 10-14-74 PERMIT NO. 298

PHONE: Business 664-4084 Home _____

LOCATION US 21 By-Pass Turn on 1305 Oates Rd. ¼ mi. JR S. R. No. _____

SUBDIVISION NAME Quail Hallow LOT NO. 2 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 ✓

Garbage Disposal Unit	Yes ( )	No ✓	
Auto. Dishwasher	Yes ✓	No ( )	
Auto. Wash. Machine	Yes ✓	No ( )	
Site Suitable	Yes ✓	No ( )	

Lot Area 22,910 Sq feet

Character & Porosity of Soil Fine Sandy Clay loam Porosity Fair
Percolation Rate not taken
Topography 2% slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 270
Depth of Stone in Lines 10"
Water Supply: Individual ✓
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-14-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold