IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 — MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

132/99 — also

PERMIT# 27792/132/99 PIN# 4657 19 46 76 — 704 664 3759

OWNER OR CONTRACTOR Jeff & Debra Seymour PHONE: Business 947-4951 Home 660-8686 DATE 6-2-05

ADDRESS 4430 Rock Stream Dr Charlotte, NC 28269

LOCATION Hwy 21 North TL Oates Rd TR Quail Hollow at end

SUBDIVISION Quail Hollow BLOCK / SECTION ____ LOT ____ LOT AREA ____ SITE CLASS. 45 DESIGN FLOW 480gpd / 360gpd L.T.A.R. .25 to .3

Septic Tank: 1000 Gallons; STB 825 Date 11-1-05

Pump Tank: ____ Gallons; PT ____ Date ____

Pump Make: ____ Model 900+ Serial No. 300+

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet ~~400~~ 300

No Lines ~~8~~ 5 Trench Width 36" Max Trench Bottom Depth 28"

X New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Gravity – 25% Reduction (Accepted System)

Repair System Description: PPP (see note)

Maintenance Agreement Required: ☐ Yes X No

Gravel Depth N/A ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing X Basement wo/plumbing

X House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms 3 No. Employees ____

Water Supply: X Individual ☐ Public ☐ Community

Comments:/Conditions: Reviewed Floor plan 10/25/05, essentially in Compliance w/ the Original permit. PL-32.5

Scale 1:60

Comments:/Conditions: * Note: lot created prior to 1983

Stay 10' from PL, 15' from Gulley & >50ft to well.

** Stub out plumbing high

INITIAL SITE SKETCH

Quail Hollow Rd

Well

PL

50'

15

Proposed House 40'x84'

Drive

Flow Divider

ST

Shallow

Creek

Gulley

15' setback

PL 409.92

AS BUILT SKETCH

Changed to 3 Bdrm 10/25/05

Installed Quick 4 For Drainfield

300 Ft

PL

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Debra Seymour date 6-6-05

Improvement Permit by: Maria H. Johnson RS date 6/2/05

Authorization to Construct by: Maria H. Johnson RS date 10/25/05

Installed by: Rowan Septic

Operation Permit by: Maria H. Johnson RS date 1/31/06

Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK