4657263/29

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S. Wyatt Neel DATE 12/14/87 PERMIT NO. _____

PHONE: Business _____ Home 664-4779

LOCATION Rt 150W TR 21N TL b/f Mooresville H2O Treatment Plant Bear R. Immediate on Lt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 9.79 ACRES

Character & Porosity of Soil Clayey (fine silt)
Percolation Rate 7.35 gpd/ft²
Topography 4-8%
Depth to Water Table 4'+
Rock or other impervious formations none observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System N.T.S. (WATER PLANT)

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: Home is near the old Mooresville City landfill.

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 12/14/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

M.D. 767

3:00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S. Wyatt Neel DATE 11/9/87 PERMIT NO. _____

PHONE: Business _____ Home 664-4779

LOCATION 150 W TR 21 N TL b/f Water Treatment Plant. Bear R. on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 9.79 ACRES

Character & Porosity of Soil Clayey (King silt) ACP


Percolation Rate .4 gpd/ft² .35 gpd/ft²

Topography 4-8%

Depth to Water Table 4'+

Rock or other impervious formations none observed.

OWELL Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System N.T.S.

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 115 x 3 = 345

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: S. Wyatt Neel

IMPROVEMENTS PERMIT BY Andie C. Price

COMMENTS: SET TANK HIGH UP HILL AS POSSIBLE TO GET FALL TO TANK. RUN LINES ON CONTOUR & SHALLOW (30" deep) CONSISTENT DEPTH AND COVER.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold