3:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECT.

PERMIT# 5714 - MOORESVILLE PIN# 4657473656 DATE 1/7/99

OWNER OR CONTRACTOR CALVARY COMMUNITY CHURCH PHONE: Business 664-3540 Home

ADDRESS PO BOX 1312 MOORESVILLE NC 28115

LOCATION HWY 150 W - 21 N - ON RT BEFORE BRANTLEY ACRES ≈ 365 ft OFF OF ROAD

SUBDIVISION - BLOCK / SECTION - LOT - LOT AREA 7.09AC SITE CLASS. PS DESIGN FLOW 1250 GAD L.T.A.R. ~.3 gpd/ft²

Septic Tank: 2000 Gallons; STB 633 Date 6/19/99

Pump Tank: 2500 Gallons; PT 96 Date 9/13/99

Pump Make: MYERS Model ME509-11 Serial No.

Nitrification Field: No Fields 1 Square Feet 4095 Linear Feet 1365

No Lines 12 Trench Width 36" Max Trench Bottom Depth 24" Gravel Depth 12"

☑ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: PUMP CONVENTIONAL

Repair System Description: PUMP 25% REDUCTION

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☑ Other CHURCH / 250 MEMBERS

☑ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions: SEPTIC CONTRACTOR SHALL CONTACT HEALTH DEPARTMENT BEFORE INSTALLATION

Comments:/Conditions: Cheaked all lines 10/26/99 MA

Pressure cheaked 10/28/99 mp

INITIAL SITE SKETCH

SEE SITE PLAN

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: RS date 1/7/99

Authorization to Construct by: RS date 1/7/99

Installed by: RICHARD ABER NATHY

Operation Permit by: RS date 1/31/00

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD