4657483426

II

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Meyers DATE 7-10-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION S/N. TR private dirt rd. ~ 1/4 mile past NBSU- Water treatment plant S. R. No. _____

SUBDIVISION NAME Brantley prop. LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20000 sq ft

Character & Porosity of Soil clay
Percolation Rate 4-35 4-8%
Topography 4 ft
Depth to Water Table _____
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1371 Linear Ft. 457
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Harvey Featherman Services Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D R Hinson R.S. DATE 7-10-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

11.'30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William Meyers DATE 5-13-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 N TR private dirt road ~ 1/4 mile past water treatment plant ~500' on left S. R. No. _____

SUBDIVISION NAME Brantley property LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20000 ft2

Character & Porosity of Soil clay
Percolation Rate ~35
Topography 4-8%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 1371 Linear Ft. 457
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
Well already down

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: W.H. Meyers

IMPROVEMENTS PERMIT BY [redacted] David R. Hinson, RS.

COMMENTS: Keep drainfield shallow (~12" cover). Divert surface water around system.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold