4657590644

05114

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Lucas DATE June 7, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N. TR 1306 (Rhinehardt Rd.) TR Northwood Estates Bear left near end on Rt. S. R. No. _____

SUBDIVISION NAME 206 Red Dog Lane LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ OK	Yes (✓)	No ( )	

Character & Porosity of Soil clay
Percolation Rate 2.4
Topography 6-8%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area 1 Ac +

_____ Basement with Plumbing ___✓___ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by AJ Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY KRS

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature], RS. DATE June 7, '88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Lucas DATE 8-1-86 PERMIT NO. 341

PHONE: Business _____ Home _____

LOCATION 115 N, Lf on Rinehardt, Rt into Northwood Estates, Lf at Vee Cross Culvert, To end of road in woods S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1 1 acre+

Character & Porosity of Soil clayey
Percolation Rate 0.5 gpd/ft²
Topography 4-6% in septic area
Depth to Water Table 4'+
Rock or other impervious formations None Noted

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 960 Linear Ft. 320
Depth of Stone in Lines 12"
Water Supply: Individual (✓) To be drilled
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed John J Lucas

IMPROVEMENTS PERMIT BY Keith Sheets R.S.

COMMENTS: Keep system no deeper than 30". Keep well 50' from septic tank & lines.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold