DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Dan Duckworth APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10/28/04
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 3bed PROPERTY SIZE: _____
LOCATION OF SITE: L 18 Sunshine Estates PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Front 1-7%	0-6	MM SBK / cl	FR SS-SP					
		7-22	FM SBK / mic cl	VFR-SS-SP	FR				
		23-32	FR GR / l SAP	VFR-NS-NP	GL YR				.25
2	Middle 10%	0-8	MC SBK / scl	FR SS-SP					
		9-30	MM SBK / cl	FR SS-P					
		31-34	GR	VFR-NS-NP			PS		.3
3	Rear-R 7-8% T	0-17	MS SBK / cl	FR SS SP					
		18-25	WM SBK / cl	FR SS SP					
		26-49	SM GR / l SAP	VFR NS-NP			PS		.3
4	Rear T 7-8%	0-15	MM SBK / c	FR SS-SP					
		16-34	MF SBK / cl	FR SS-SP					
		35-49	SM GR / l SAP	VFR NS-NP					.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PPBRS	PPBRS

OTHER FACTORS (.1946): Stream on (L)
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Spears
OTHER(S) PRESENT: Tony Swanson / Duckworths