DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: IM 16 B19
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BROADMOOR HOMES OWNER: ✓ AGENT: PHONE: 663-7660
ADDRESS: PO BOX 1242 APPLICATION DATE: 6/24 DATE EVALUATED: 6/24
MOORESVILLE, NC. PROPOSED FACILITY: 3BD.
PROPERTY SIZE: .98
LOCATION OF SITE: KETCHIE DR + SUNSHINE DR. ON (R)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	P	0-8	WKSGR/C	1:1	S	S	S	—	.2-.25
		9-21	VWK SBK/C TRANS	1:1	S	S	S	—	
		22-34	SBK/SIC TRANS	1:1 F	S	P	P	P	
		34-42	WSBK/SIC TRANS	1:1 F	S	P	P	II	
2									
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25
EVALUATED BY: SPARKS OTHER(S) PRESENT: PAUL BROAD BENT
COMMENTS: