2094

IREDELL COUNTY HEALTH DEPARTMENT

4657-79-2734

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR O. N. BELK DATE 10/6/92 PERMIT NO. IM-16-A-12

PHONE: Business _____ Home 663-1638

LOCATION NORTH ON RHINEHARDT RD FROM HWY 150, T/L SUN LANE, LOT ON LEFT

S.R. No. _____

SUBDIVISION NAME KETCHIE ACRES LOT NO. 12 SECTION OR BLOCK NO. II

House ☒ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☒

Auto. Dishwasher Yes ☒ No ☐

Auto. Wash. Machine Yes ☒ No ☐

Lot Area 20,000 sq'

Soil Characteristics PS-WK MOD TO CRS SBK; FI IN TOP 25"


Application Rate 0.4 LTR/FT IN TOP 25"

Topography S

Depth to Water Table >36"

Rock or other impervious formations >36"

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2 (150' x 3')

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☒ INSTALLED

Public ☐

CASE DEPTH 45' 10-29-92

DIA 6" REQ. NO 195

GRAVEL INT. 20' DEPTH 165'

STATIC LEVEL 30' YIELD 50 gpm

Installed by NELSON HATHCOCK

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY ANDREA Lemon & DAVID HINSON

COMMENTS INSTALLED PER DIAGRAM + INSTRUCTIONS

FILL + LANDSCAPING VERY NICE, GENEROUS. NO GUTTERS

INSTALLED - RECOMMENDED - BUT THERE IS PROBLEM W/ DISCHARGE

PAINT. FLOW DIVIDER TEE LEVELED AND DITCH BACKFILLED + PACKED W/ SAND

CERTIFICATE OF COMPLETION BY Andrea S Lemon, RS DATE 12/16/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold