4:00

IREDELL COUNTY HEALTH DEPARTMENT Const. Auth

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / ~~CERTIFICATE OF COMPLETION~~ / OPERATION PERMIT / EXISTING SYSTEM INSPECT

PROPERTY DESCRIPTION NO. 24598 DATE Aug 18, 97 TAX MAP NO. part of 1145 Watershed: ☐ Yes ☐ No

OWNER OR CONTRACTOR Kson Financial Services PHONE: Business 1643671 Home 4658-00-2779

ADDRESS 149 Yacht Cove Rd. Mooresville

LOCATION US 21 N TL Valleyview on left At end

SUBDIVISION Oakbrooke BLOCK / SECTION ____ LOT 19 LOT AREA .81AC SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .4 (Saprolite)

Septic Tank: 1000 Gallons; STB 525 Date 8/21/97

Pump Tank: ____ Gallons; PT ____ Date ____

Pump Make: ____ Model ____ Serial No. ____

Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300

No Lines 4@75' Trench Width 36" Trench Bottom Depth 42" min Gravel Depth 12" / 18" Stone

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: grav. conv. / Sand Lined trench

Repair System Description: same

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees ____

☐ Other ____

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply:
☑ Individual
☐ Community
☐ Public

Comments:

Comments:

INITIAL SITE SKETCH

SEE PLAN by TC Jacobs and Assoc.

AS BUILT SKETCH

SAME AS PLAN

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: * R Gronow

Improvement Permit by: DR Thompson RS date 8-18-97

Construction ~~Repair~~ Inspection by: DR Thompson RS date 8-18-97

Authorization

Installed by: Rowan Septic

Certificate of Completion by: ____ date ____

Operation Permit by: C. Bailey Freeman RS date 10/7/97

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD