DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kerr — APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-17-97
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 17 Oakbrook — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Now Lot 14

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941): 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PRACTICE FACTORS: 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1980 SAPRO CLASS	1941 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	RS 2-4%	0-11	sab bnR cl	fr					PS 3 @ ≤ 30"
		11-30	m-wksab R mod R cl w/ mod sap/pr						
		30-65+	wksab c bnred/gy sap						
2	RS 2-4%	0-18	sab p-ban, bRw scl fr						PS 3 @ ≤ 30"
		18-32/36	sab RC	fr SO sap					
		32/36-48+	wksab p-ban, gbnd clay						
			trans to SPR sap						
3	RS 2-4%	0-32	m-ssab R c/cl	fr SO sap					PS 3 @ ≤ 30"
		32-48+	wksab RPL	fr SO sap					
			w/mod sap/wk						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____