DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

# SOIL/SITE EVALUATION
## *for* ON-SITE WASTEWATER SYSTEM

OWNER: Knorr
ADDRESS: _____
PROPOSED FACILITY: _____
LOCATION OF SITE: Lot 25 Nebraska
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

APPLICANT: _____
APPLICATION DATE: _____
PROPOSED DESIGN FLOW (.1949): _____
DATE EVALUATED: 10-24-96
PROPERTY SIZE: _____
PROPERTY RECORDED: _____

Now 22

| PROFILE # | 1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE | SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | L 6-8% | 0-11" | Sg fbrn SL | fr | | | | | P n3 @ < 30" |
| | | 11-30" | Sab R c/cbl | fr sp sap | | | | | |
| | | 30-43" | wk sab-massive | brn/gy sap fr sp sap | | | | | |
| 2 | L 8-10% | 0-6 | gr fbrn sl | fr | | | | | P3 n3 @ 24" |
| | | 6-31 | Sab R | fr sp sap | | | | | |
| | | 31-88 | mod sab R cbl | fr sp sap | | | | | |
| 3 | L 10-12% SLOPED | 0-6 | sl fbrn sl | fr | | | | | P5 n3 @ 36" |
| | | 6-36 | sab R c/cbl | fr sp sap | | | | | |
| | | 36-43 | mod sab R cbl | fr sp sap | | | | | |
| 4 | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | | |
| System Type(s) | | |
| Site LTAR | | |

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____