DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Krom APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-24-25
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 31, Oakbrook PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

WOW 27

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L-C 4-6%	0-30/25 sdb reddish scl fr ss sp sap 30/25+ 253+ marine RC lsap vfi ss sp sp							PS-4 @ 30"
2	L 4-10%	0-22 sdb rd lay sandy clay loam 22-48/+ marine mottled lsap vfi				w			
3	L 4-10%	0-18/23 sdb reddish scl fr ss sp sap 18/23 marine C sap/ hard rock				w			
4	L 4-10%	0-18 gr brn scl/sc C 18-30+ hard saprolite marine				w			

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kamm
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 10-25
PROPOSED FACILITY: _____
PROPOSED DESIGN FLOW (.1949): _____
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 31 continued Oakbrook
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

now 27

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
#5 F	L 10%	0-15	sa lo scl	fr		42			
		15-36+	sa lo scl + landw/ saprmp						
#6	L 1-5%	0-15/17	sa lo scl	fr					
		15/17+	landw/ saprmp						
#7	L 15-20%	0-24/30	sa lo, scl/scl	fr/sl sm/sp	mottles 6-12" below surface				PS .3 @ 24-30"
#3		24-36+	w/soft REL w/wet wea/R	fr/sm/sp					
#8	L 15-20%	0-12	sa lo light cl						PS .3 @ 32+
#4		12-32	sa lo scl						
		32+	cl sm/sp						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

#9 0-36 light cl fr/sm/sp PS .36
36-48 compact w/c

#10 0-32 sa lo scl fr/sp/ssp mottles at 20" PS .34
32-48+ w/ sand