IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 136217 PIN# 4658 07 ~~9414~~ 9414 DATE 6/22/06

OWNER OR APPLICANT Corinthian Builders LTD. PHONE: Business 704 400 1258 Home

ADDRESS PO Box 990 Denver, NC 28037

LOCATION 21N TL Barkley Rd. TR Olympia Dr. 2nd lot on R

SUBDIVISION Cornelius Estates BLOCK / SECTION LOT 72 LOT AREA .7 Ac SITE CLASS PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 786 Date

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 480 Linear Feet 240

No Lines 2 @ 40 Trench Width 2' Max Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II ☒ III IV V VI

System Description: CenterFed 16" PABPS

Repair System Description: Same Type

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 3 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Trench depth must be 36" depth.

Site Plan and Layout done by S+EC

Comments/Conditions: 9/25 - Lawn

INITIAL SITE SKETCH

See Attached Plan from S+EC Concord.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Melissa Neal date 6-23-06

Improvement Permit by: Wesley Sparks R.S. date 6/22/06

Authorization to Construct by: Wesley Sparks R.S. date 6/22/06

Installed by: Corinthian Blders

Operation Permit by: RS date 8/30/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK