DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Krom APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 10-12-96
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Lot 16 Oakbrook PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

(now Lot 13)

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS 1943 SOIL DEPTH	OTHER PROFILE FACTORS 1956 SAPRO CLASS	OTHER PROFILE FACTORS 1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	L S 4-6%	0-26	SaCb R cfi fr	So sp so sap		48			
		26-48	wkSaCb R bnd sap						
		wavy boundary		LPS-blotch		intrusion			
2	R S 4-6%	0-13	SaCb R cfi fr						
		13-35	wkSaCb blocky cl sp/st	mangan/segregation		48			
		35-48+	wkSaCb R-blocky cl sp fr						
3	R S 4-6%	0-27/30	SaCb R cfi vfr wet/saturation						PS -3
		27/30-48+	wkSaCb cl sp						
			mangan/wk						
4	L A 4% V 2-97	0-5	Sa-SaLm structureless fr						PS -3 @ 32" = 30%
		5-18	SaCb R cfi fr so sp sap						
		18-32	SaCb blocky cl sp/st	slightly w sap-sap					
		32-48	wkSaCb R-blocky cl sp fr	sap					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___

EVALUATED BY: ___
OTHER(S) PRESENT: ___