DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Keen — APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-17-96
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 15 Cookbook PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut — NEED More Soil Info on Rear of Lot
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ	PROFILE CLASS & LTAR
1	L 1-4%	0-3	sab rbr vfr	fr-ss/sp/ss/p					PS .3 @ ≤ 36"
		3-36	sab rbr	fr ss/sp/ss/p					
		36-48	mod sab rbr-ybr	vfr/sp/ss/p					
2	L 4%	0-10	sab R-brn, brn cl	fr ss/sp/ss/p					PS .3 @ ≤ 10"
		10-20	gr-sab brn-R	sc/ fr					
		20-40	m sab R cl	fr ss/sp/ss/p					
		40-48+	wk sab mottled R brn	cl/ss/sp/p					
3	L-C 2-4%	0-27/30	sab R c/cl	fr ss/sp/ss/p					PS .3 @ ≤ 27/30"
		27/30	wk sab R brn w/ orang bts	cl/ss/sp/p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

10-17-96 Thick brn loam/peds over sand & LS - suspect hard landscape position is depth limiting.