Sheet
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Kraus
APPLICANT:
APPLICATION DATE: DATE EVALUATED: 3/10/92
ED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
ON OF SITE: Lot 51 Emerald Oakwood PROPERTY RECORDED:
R SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
UATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	V ~8%	0-3	Sa-sl-scl						PS e 3-35 e ≥ 36"
		3-12	SaSlo RC	fi sl stru					
		12-36	M-wl gleb scl	fri sl stp					
		36-46+	wl sa lenses	sl stp					
2	V ~8%	0-3	gr-sa lo loam scl						PS e 3-35 e ≥ 36"
		3-17	Sa lo RC	fri sl stp					
		17-36	M Sa lo RCL	fri sl stp					
		36-48	wl sa lo loam RCL	fri sl stp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Space (.1945)		
Type(s)		
LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: