DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kay Gibson - Randy Gibson
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): 360gpd DATE EVALUATED: 1-20-06
LOCATION OF SITE: Hwy 21 N TL Barfield TL M&M Farms PROPERTY SIZE: 47 Ac
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9%	0-5	lsbk l			38			PS .3
		5-25	lsbk cl	fr ss/sps e					
		25-38	lsbk cl + sl sap						
		38-48	sl sap						
2		0-4	lsbk sl			45			PS .3
		4-36	lsbk cl						
		36-45	lsbk cl + sl sap						
		45-48	sl sap						
3		0-6	lsbk sl			48			PS .3
		6-30	lsbk cl						
		30-48	lsbk scl	brown					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	Yes	Yes
System Type(s)	conv.	conv.
Site LTAR	.3	.3

COMMENTS:

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: J. Melville
OTHER(S) PRESENT: _____