4658-30-3556

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rufus Dalton DATE 9-4-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N. on left ~ 1/2 mi. past Mtville H2O treatment plant S. R. No. _____

SUBDIVISION NAME Countryside Estates LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area ~30,000 ft²

Character & Porosity of Soil clay
Percolation Rate ~.35
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none observed – numerous relic mottling

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NTS.

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 1029 Linear Ft. 343
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

(Installed by) Larry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Used speed levelers in line 4 & 5 to maintain proper distribution.

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 9-4-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold