4658303638

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RUFUS DALTON DATE 12/31/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N. ON LEFT ~ 1/2 mile past MOORESVILLE WATER TREATMENT PLANT S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Clay
Percolation Rate ~35 gpd/ft²
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area 115' X 197'

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1029 Linear Ft. 343
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Larry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Pierce DATE 12/31/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

07280

1:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rufus Dalton DATE 8-26-87 PERMIT NO.

PHONE: Business Home

LOCATION 21 N. on left ~ ½ mile past Mooresville water treatment plant S. R. No.


SUBDIVISION NAME LOT NO. (2) SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 115' X 197'

Character & Porosity of Soil Clayey
Percolation Rate ~.35 gpd/ft²
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System N.T.S.

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1029 Linear Ft. 343'
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Rufus M Dalton

IMPROVEMENTS PERMIT BY Andre C Price

COMMENTS: Install lines on contour and stay uphill as much as possible. Run lines with SHALLOW depth. (24" - 30" max. trench depth) Leave max. repair area below (down hill from) original installation.

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold