DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____ OF____
PROPERTY I.D.#:____
PROPERTY RECORDED:____
COUNTY:____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Billy Jones / Bill Ball OWNER:__ AGENT:__ PHONE:____
ADDRESS: 62 Thousand Oaks West APPLICATION DATE:____ DATE EVALUATED: 6-14-95
PROPOSED FACILITY: 360 gpd SFR
PROPERTY SIZE: .99 ac +/- 105' x ≈ 380'
LOCATION OF SITE: Lot 6 Turnstake phase 1 on Barley Trail
WATER SUPPLY: On-Site Well ✓ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Terraced LSS 10-15%	0-13	SaSb - C Red	1:1 fi					.3
		13-24	wksab & Red clay mottles	1:1 fr					
		24-48	well wt. sap	1:1 vfr					
2	Terraced LSS 10-15%	0-6	wksab cl	1:1 slightly sp					.3
		6-15	SaSb - Red clay	1:1 fi					
		15-26	mod sab cl some sand	1:1 fr					
		26-40	wksab - sandy loam	1:1 vfr					
		40-48	well wt. sap.						
3									
4									
5									

AVAILABLE SPACE (.1945): 3/4 SITE CLASSIFICATION (.1948):____ SITE LONG-TERM ACCEPTANCE RATE:____
EVALUATED BY: HWK OTHER(S) PRESENT:____
COMMENTS:
Need backhoe pits

529-8821

DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bill Jones OWNER: ____ AGENT: ____ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 6/27/95
PROPOSED FACILITY: 3 bed spa SFR
PROPERTY SIZE: 1.99 ac
LOCATION OF SITE: lot 6 Farmdale
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-5	SSbk- loam/cl	fi					.3
		5-23	wksbk- cl w/some gravel	fm					
		23-48	w.w. sap- loam to	vfm					
2		0-4	SSbk- c	fi					.3
		4-20	wksbk- cl	fm					
		20-36+	w.w. sap- loam	vfm					
3		0-4	gr-wksbk- scl	fi					.3
		4-18	SSbk- c	fi					
		18-48+	wksbk- cl w/ some gravel & some mangan. nodules	vfi					
4									
5									

AVAILABLE SPACE (.1945): ____ SITE CLASSIFICATION (.1948): 48 SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: 1 trench ok - will require 1 moveable aeration unit
6/29/95 contour or straight access 5@80' conv. w/ like repair