DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bill Zorec / Bob Bell OWNER: __ AGENT: __ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 6-14-95
PROPOSED FACILITY: 3 bdrm SFR
PROPERTY SIZE: 1 Ac
LOCATION OF SITE: Lot 5 phase 2 Jamestown on Bonnard.
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1 HH	1-2% interfluve upper 1/3	0-5	SaSi- c (red)	1:1					
		5-17	wk SaSi- L (red)	1:1 SS, NP					
		17-48	well wk SaSi (red-gy)	1:1 gr-vfr					
2 HH	Toe 1-2% 10-15%	0-12	mod wk SaSi- cL	1:1 m-fi					
		12-28	wk SaSi- L						
		28-48	wk SaSi- L (red-gy) very wk-wk						
3									
4									
5									

AVAILABLE SPACE (.1945): A SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____
EVALUATED BY: HH OTHER(S) PRESENT: ____
COMMENTS: Need location on B

DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bill Jones OWNER: ___ AGENT: ___ PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 6/27/95
PROPOSED FACILITY: 3 bedroom
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 5 Farmdale
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit (X) Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-18	vk sbk cl w/ mica	mf.					.3
		18-48+	wet sap- loamy w/ seam of	vfr					
2		0-2	gr sl	fr					.3
		2-12	sbk cl	fi					
		12-22	vk sbk (fac) loam	fr					
		22-48+	loamy sap	vfr					
3		0-25	msbk cl	mfi-fr					.3
		25-48+	vwp sap- loam	vfr					
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): SC SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] OTHER(S) PRESENT: ___
COMMENTS: Unsuitable soil material encountered within 48" of ground surface