4658 464183

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John M. Byars DATE 8-9-78 PERMIT NO. 193

PHONE: Business _____ Home _____

LOCATION 21A TL on 1308 1 mi on Left

S. R. No. _____


SUBDIVISION NAME Green Meadows LOT NO. 8 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	45 min/in
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2% to Side
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'
			Rock or other impervious formations	None

Lot Area 2 1/2 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by F.J. Ervin

IMPROVEMENTS PERMIT BY _____

COMMENTS: One Ditch had 10" Fall Put Earth Dam half way in Line

CERTIFICATE OF COMPLETION BY John Houston DATE 8-9-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold