DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ronald Mills APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 4/16/98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10"	Brn SCL GR	FR					PS .3
		10"-30"	Rd/Brn C/CL	M-W SBK S-SS,SPS-SE,FI					
		30"-HR	Rd/Brn CL	W SBK SS,SP,SE,FR					
			SAP indus						
2		0-10"	Brn SL GR	FR					PS .275 .3 Flakes
		10-34"	Rd/Brn C/CL	M-W SBK S-SS,SP,SE,FI					
		30-40"	Rd/Brn C	W/Indus of SAP & weathered Rock					
			SAP & weathered	Rock indus, Common Mica Flakes					
		40"-48"	Weathered Rock	SAP & Mica Flakes					
3		0-10"	Brn SCL GR	FR					PS .3
		10"-36"	Rd/Brn C/CL	SS,SP,SE,FI-FR w/few to many SAP & weathered Rock					
		36"-HR	SAP/weathered Rock	w/Indus.					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____