DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF____
PROPERTY I.D.#:____
PROPERTY RECORDED:____
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: BILL BALL OWNER: ✓ AGENT:__ PHONE:____
ADDRESS:____ APPLICATION DATE:____ DATE EVALUATED: 12/6/96
PROPOSED FACILITY:____
PROPERTY SIZE:____
LOCATION OF SITE: FAIRDALE LOT 25
WATER SUPPLY: On-Site Well ✓ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	.1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	40%	0-4	SCL BR	FRI SS,SP					PS 13 to 36"
		4-36	CL MSBK	FRI SS,SP					
		36-48	CL - INCLUSIONS	OF WEATHERED ROCK					
2	40%	0-8	SCL BR	FRI SS,SP					PS .3 to 38"
		8-38	CL MSBK	FRI SS,SP					
		38-48	CL - INCLUSIONS	OF WEATHERED ROCK					
3									
4									
5									

AVAILABLE SPACE (.1945) 100 FT SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: Bradley Teer OTHER(S) PRESENT: BELL BALL
COMMENTS: Keep trenches 24" deep at maximum