DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

KENNY

APPLICANT: Tonya Faust / Jeff Arrington OWNER: ____ AGENT: ____ PHONE: 664-4268
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 5/12/94
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Jones Rd at end
WATER SUPPLY: On Site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS	0-6"	SAB / CL	1:1 / fr					.3
		6"-24"	SAB / C	1:1 / fi					
		24-48	~~SAP~~ trans / sicl	1:1 / fi-vfi					
			wk SAB						
2	LS	0-6	SAB / scl	1:1 / fr					.3
		6-25	SAB / C	1:1 / fi-vfi					
		25-45	wk SAB / sicl	1:1 / fi-fr					
			sap trans.						
3	SS	0-3	gr-SAB / scl						
		3-20	wk SAB / sicl sap trans.						
		20+	Saprolite						
4	CC	0-5	LS	1:1 FR	P				
		6-27	scl	1:1 FR SS SP	P				
		28-42	c / TRANS.	1:1 FI S SP	P	42-44 SAP.			
5		0-10	sl	1:1 S FR					
		11-23	sic	1:1 FR SP					
		24-32	sicl TR.	1:1 NS SP		30-31 SAP-SP			

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: ____