4058532591

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Davco Country Market DATE 7/7/86 PERMIT NO. 402

PHONE: Business _____ Home _____

LOCATION 150W, Rt on 21 N, 1mile on Rt

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (X) Other _____


No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )

Lot Area 1acre+

Character & Porosity of Soil clay loam - clay
Percolation Rate 2-59pd/ft²
Topography 2-6%
Depth to Water Table 4ft
Rock or other impervious formations None Noted

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



2 Plot of System

Size of Tank 1500+1500 Gals. Greasetrap
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Rowan Septic

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred A. Clemmer RS

COMMENTS: ~~System is sized for convenience store w/o food Prep. Additional line must be added to system to accomodate food prep.~~ System OK for deli/hotdog operation w/ No Seats KCS 7/11/86

CERTIFICATE OF COMPLETION BY Kelly R. Shook RS DATE 7/7/86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

Raven Septic 2:00 2

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Danco Country Market DATE 12-31-85 PERMIT NO. 410

PHONE: Business _____ Home _____

LOCATION 150 W TR Hwy 21 North ~ 1.5 mile on R before 1302

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House ( ) Mobile Home ( ) Business (X) Other PACKAGE SANDWICH'S ONLY - NO FOOD PREP ON SITE

No. Bedrooms PROP. LINES No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 1 ACRE+

Character & Porosity of Soil CLAY-LOAM


Percolation Rate 0.5 GAL/FT/day

Topography 2-6%

Depth to Water Table 4'

Rock or other impervious formations NONE OBS.

_____ Basement with Plumbing _____ Basement without Plumbing (X) No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (X)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Mike Davis

IMPROVEMENTS PERMIT BY Mark Clemmer

COMMENTS: Keep system shallow, follow contours, do not drive over septic tank

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold