COPY

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 164358 PIN # 4658-53-3676 DATE 1-13-10

OWNER or APPLICANT CICERO SULLIVAN PHONE: Business 704-660-5528 Home:

OWNER or APPLICANT ADDRESS 338 SHEPHERD RD MOORESVILLE NC 28115

LOCATION / DIRECTIONS 2179 CHARLOTTE HWY

SUBDIVISION BLOCK / SECTION LOT # LOT AREA .66 AC DESIGN FLOW 384 GPD L.T.A.R. .25

Septic Tank 1000 Gallons: STB 760 Date 726

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 6 Linear Feet 258'

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth 16" SAND

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: PANEL BLOCK

Repair System Description: SAME

Maintenance Agreement Required ☐ YES ☐ NO

☒ GRAVITY ☐ PRESSURE

☐ Residence No. Bedrooms

☒ Business No. Persons

☐ Other No. Employees 4

☐ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☐ Community

Comments / Conditions ① OLD TANK TO BE REMOVED & SUITABLE SOIL PUT IN HOLE ② MIN 5' TO FOUNDATION ③ NO PARKING ON SEPTIC AREAS ④ NO FOOD SERVICE

Comments / Conditions DESIGN FLOW = 120 GPD PER 1000 SQFT RETAIL AREA / 120 X 3.2 = 384

INITIAL SITE SKETCH

≈ 1"=40'

10 PANELS PER LINE INSTALLED AS SHOWN

OKED MOVING TANK PRIOR TO INSTALLATION

100% REPAIR

139'

43'

43'

43'

43'

5'

10'

AS BUILT SKETCH

209'

WELL

BUILDING

PARKING

138'

HWY 21

NEW TANK

209'

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 1-19-11

Improvement Permit by: REHS Date 1-19-11

Authorization to Construct by: REHS Date 1-19-11

Installed by: BACKHOE

Operation Permit by: REHS Date: 2-2-11

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant