DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bobby Christie OWNER: ___ AGENT: ___ PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 9/29/95
PROPOSED FACILITY: repair for water
PROPERTY SIZE: ____

LOCATION OF SITE: ____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-12	gr lam sL	fr					.3
		12-32	subb R-sg C'	fr sl p.					
		32-48	m-ck subb - R-sg cl	fr					
2									
3									
4									
5									

AVAILABLE SPACE (.1945) ____ SITE CLASSIFICATION (.1948): ____ SITE LONG-TERM ACCEPTANCE RATE: ____
EVALUATED BY: ____ OTHER(S) PRESENT: ____
COMMENTS: use ~100' for water w/ 75 gal tank