4658-84-1979

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Quercash DATE 8-28-80 PERMIT NO. 272

PHONE: Business _____ Home _____

LOCATION 115N TR 2406 Bear left on 2406 on R just before duck house S. R. No. _____

SUBDIVISION NAME Collins Park LOT NO. 7 SECTION OR BLOCK NO. A

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes ( ) No (X)
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Lot Area 17,000ft2

Character & Porosity of Soil Clay loam.
Percolation Rate 30-120 mpi
Topography 2-6%
Depth to Water Table unknown
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement Without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16
Water Supply: Individual ( )
Public (X)
Water from Next door

Installed by Eddie Younce

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY FAK

COMMENTS: Oked layout Change

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 8-28-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold